



King County Fire Marshal's Office
Department of Development and Environmental Services
900 Oakesdale Avenue Southwest Renton, WA 98055-1219 (206) 296-6675

Permit No. F02-0018

CASCADE AIRFRAME
8500 PERIMETER RD S
SEATTLE, WA 98108

RECEIVED
KING COUNTY
APR 17 2002
INTERNATIONAL
AIRPORT

Date Expires: 01/15/2003

Business Name: CASCADE AIRFRAME
Site Address: 8500 PERIMETER RD S BF
Fire District: KCA
Location:

*Please file in
each applicable
tenant base
file.
maurice*

THIS PERMIT IS GRANTED FOR:

Cond: CON1218445

AIRCRAFT HANGERS, REPAIR: Repairing aircraft requiring the use of open flames, spark-producing devices or the heating of parts above 500 degrees C, shall be done in the open or in an area conforming with the Building Code for a Group H, Division 5 Occupancy.

Cond: CON1218444

Flammable Liquids: >5 lbs Inside

Cond: CON1218446

Hot Work Operations; CUTTING & WELDING

NOTICE

1. This permit does not take the place of any License required by law and is NOT TRANSFERABLE. Any change in use, occupancy, or ownership of the premises shall require a new permit.
2. THIS PERMIT AND ANY ATTACHED CONDITIONS MUST BE POSTED IN A CONSPICUOUS PLACE ON THE PREMISES.
3. This permit is subject to the satisfactory completion of all corrections identified in the original or renewal inspection and all conditions that are attached.
4. This permit EXPIRES (01/15/2003)
5. Call 296-6675 for inspection requests and information regarding this permit.